


# Standard Groove Specifications

## STANDARD ROLL GROOVE SPECIFICATIONS FOR STEEL AND OTHER IPS PIPE †



### Standard Roll Groove Specifications

1	2		3		4		5		6	7	8
	Dimensions – Inches/millimeters										
	Pipe Outside Dia. O.D.		Gasket Seat - A ±0.03 ±0.76	Grv. Width - B ±0.03 ±0.76	Groove Dia. – C		Groove Depth D (ref.)	Min. Allow. Wall Thk. T	Max. Allow. Flare Dia.		
Basic	Tolerance + –	Basic			Tol. +0.00 +0.00						
3/4 20	1.050 26,9	0.010 0,25	0.010 0,25	0.625 15,88	0.281 7,14	0.938 23,83	-0.015 -0,38	0.056 1,42	0.065 1,65	1.15 29,2	
	1 25	1.315 33,7	0.013 0,33	0.013 0,33	0.625 15,88	0.281 7,14	1.190 30,23	-0.015 -0,38	0.063 1,60	0.065 1,65	1.43 36,3
1 1/4 32	1.660 42,4	0.016 0,41	0.016 0,41	0.625 15,88	0.281 7,14	1.535 38,99	-0.015 -0,38	0.063 1,60	0.065 1,65	1.77 45,0	
	1 1/2 40	1.900 48,3	0.019 0,48	0.019 0,48	0.625 15,88	0.281 7,14	1.775 45,09	-0.015 -0,38	0.063 1,60	0.065 1,65	2.01 51,1
2 50	2.375 60,3	0.024 0,61	0.024 0,61	0.625 15,88	0.344 8,74	2.250 57,15	-0.015 -0,38	0.063 1,60	0.065 1,65	2.48 63,0	
	2 1/2 65	2.875 73,0	0.029 0,74	0.029 0,74	0.625 15,88	0.344 8,74	2.720 69,09	-0.018 -0,46	0.078 1,98	0.083 2,11	2.98 75,7
76,1 mm	3.000 76,1	0.030 0,76	0.030 0,76	0.625 15,88	0.344 8,74	2.845 72,26	-0.018 -0,46	0.078 1,98	0.083 2,11	3.10 78,7	
	3 80	3.500 88,9	0.035 0,89	0.031 0,79	0.625 15,88	0.344 8,74	3.344 84,94	-0.018 -0,46	0.078 1,98	0.083 2,11	3.60 91,4
3 1/2 90	4.000 101,6	0.040 1,02	0.031 0,79	0.625 15,88	0.344 8,74	3.834 97,38	-0.020 -0,51	0.083 2,11	0.083 2,11	4.10 104,1	
	4 100	4.500 114,3	0.045 1,14	0.031 0,79	0.625 15,88	0.344 8,74	4.334 110,08	-0.020 -0,51	0.083 2,11	0.083 2,11	4.60 116,8
108,0 mm	4.250 108,0	0.043 1,09	0.031 0,79	0.625 15,88	0.344 8,74	4.084 103,73	-0.020 -0,51	0.083 2,11	0.083 2,11	4.35 110,5	
	4 1/2 120	5.000 127,0	0.050 1,27	0.031 0,79	0.625 15,88	0.344 8,74	4.834 122,78	-0.020 -0,51	0.083 2,11	0.095 2,41	5.10 129,5
133,0 mm	5.250 133,0	0.053 1,35	0.031 0,79	0.625 15,88	0.344 8,74	5.084 129,13	-0.020 -0,51	0.083 2,11	0.109 2,77	5.35 135,9	
	5.500 139,7	0.056 1,42	0.031 0,79	0.625 15,88	0.344 8,74	5.334 135,48	-0.020 -0,51	0.083 2,11	0.109 2,77	5.60 142,2	
5 125	5.563 141,3	0.056 1,42	0.031 0,79	0.625 15,88	0.344 8,74	5.395 137,03	-0.022 -0,56	0.084 2,13	0.109 2,77	5.66 143,8	
	6.000 152,4	0.056 1,42	0.031 0,79	0.625 15,88	0.344 8,74	5.830 148,08	-0.022 -0,56	0.085 2,16	0.109 2,77	6.10 154,9	
152,4 mm	6.250 159,0	0.063 1,60	0.031 0,79	0.625 15,88	0.344 8,74	6.032 153,21	-0.030 -0,76	0.085 2,16	0.109 2,77	6.35 161,3	
	6.500 165,1	0.063 1,60	0.031 0,79	0.625 15,88	0.344 8,74	6.330 160,78	-0.022 -0,56	0.085 2,16	0.109 2,77	6.60 167,6	
165,1 mm	6.625 168,3	0.063 1,60	0.031 0,79	0.625 15,88	0.344 8,74	6.455 163,96	-0.022 -0,56	0.085 2,16	0.109 2,77	6.73 170,9	
	8.000 203,2	0.063 1,60	0.031 0,79	0.750 19,05	0.469 11,91	7.816 198,53	-0.025 -0,64	0.092 2,34	0.109 2,77	8.17 207,5	

† On roll grooved pipe, Allowable Pipe End Separation and Deflection from Centerline will be 1/2 values listed for cut grooved pipe. For 30 - 42" (750 - 1050 mm) roll groove dimensions contact Victaulic.

COLUMN 1: **Nominal IPS Pipe size.**

COLUMN 2: **IPS outside diameter.** The outside diameter of roll grooved pipe shall not vary more than the tolerance listed. For IPS pipe the maximum allowable tolerance from square cut ends is 0.030" for 3/4 - 3 1/2"; 0.045" for 4 - 6"; and 0.060" for sizes 8" O.D. and above measured from true square line.

COLUMN 3: **Gasket seat.** The pipe surface shall be free from indentations, roll marks, and projections from the end of the pipe to the groove, to provide a leak-tight seal for the gasket. All loose paint, scale, dirt, chips, grease and rust must be removed. It continues to be Victaulic's first recommendation that pipe be square cut. When using beveled pipe contact Victaulic for details. Square cut pipe **must** be used with FlushSeal® and EndSeal® gaskets. Gasket seat "A" is measured from the end of the pipe. IMPORTANT: Roll grooving of beveled end pipe may result in unacceptable pipe end flare. See column 8.

COLUMN 4: **Groove width.** Bottom of groove to be free of loose dirt, chips, rust and scale that may interfere with proper coupling assembly. Corners at bottom of groove must be radiused. For IPS steel pipe, .06R on 3/4 - 1 1/2", .08R on 2 - 6", .05R on 8" and up.

COLUMN 5: **Groove outside diameter.** The groove must be of uniform depth for the entire pipe circumference. Groove must be maintained within the "C" diameter tolerance listed.

COLUMN 6: **Groove depth.** For reference only. Groove must conform to the groove diameter "C" listed.

COLUMN 7: **Minimum allowable wall thickness.** This is the minimum wall thickness which may be roll grooved.

COLUMN 8: **Maximum allowable pipe end flare diameter.** Measured at the most extreme pipe end diameter square cut or beveled.

## Standard Roll Groove Specifications

1 Nom. Pipe Size Inches mm	2		3	4	5		6	7	8	
	Dimensions – Inches/millimeters									
	Pipe Outside Dia. O.D.			Gasket Seat - A ±0.03 ±0,76	Grv. Width - B ±0.03 ±0,76	Groove Dia. – C		Groove Depth D (ref.)	Min. Allow. Wall Thk. T	Max. Allow. Flare Dia.
	Basic	Tolerance +      -				Basic	Tol. +0.000 +0,00			
8 200	8.625 219,1	0.063 1,60	0.031 0,79	0.750 19,05	0.469 11,91	8.441 214,40	-0.025 -0,64	0.092 2,34	0.109 2,77	8.80 223,5
254,0 mm	10.000 254,0	0.063 1,60	0.031 0,79	0.750 19,05	0.469 11,91	9.812 249,23	-0.027 -0,69	0.094 2,39	0.134 3,40	10.17 258,3
10 250	10.750 273,0	0.063 1,60	0.031 0,79	0.750 19,05	0.469 11,91	10.562 268,28	-0.027 -0,69	0.094 2,39	0.134 3,40	10.92 277,4
304,8 mm	12.000 304,8	0.063 1,60	0.031 0,79	0.750 19,05	0.469 11,91	11.781 299,24	-0.030 -0,76	0.109 2,77	0.156 3,96	12.17 309,1
12 300	12.750 323,9	0.063 1,60	0.031 0,79	0.750 19,05	0.469 11,91	12.531 318,29	-0.030 -0,76	0.109 2,77	0.156 3,96	12.92 328,2
14 350	14.000 355,6	0.063 1,60	0.031 0,79	0.938 23,83	0.469 11,91	13.781 350,04	-0.030 -0,76	0.109 2,77	0.156 3,96	14.16 359,7
15 375	15.000 381,0	0.063 1,60	0.031 0,79	0.938 23,83	0.469 11,91	14.781 375,44	-0.030 -0,76	0.109 2,77	0.165 4,19	15.16 385,1
16 100	16.000 406,4	0.063 1,60	0.031 0,79	0.938 23,83	0.469 11,91	15.781 400,84	-0.030 -0,76	0.109 2,77	0.165 4,19	16.16 410,5
18 450	18.000 457,2	0.063 1,60	0.031 0,79	1.000 25,40	0.469 11,91	17.781 451,64	-0.030 -0,76	0.109 2,77	0.165 4,19	18.16 461,3
20 500	20.000 508,0	0.063 1,60	0.031 0,79	1.000 25,40	0.469 11,91	19.781 502,44	-0.030 -0,76	0.109 2,77	0.188 4,78	20.16 512,1
22 550	22.000 559,0	0.063 1,60	0.031 0,79	1.000 25,40	0.500 12,70	21.656 550,06	-0.030 -0,76	0.172 4,37	0.188 4,78	22.20 563,9
24 600	24.000 610,0	0.063 1,60	0.031 0,79	1.000 25,40	0.500 12,70	23.656 600,86	-0.030 -0,76	0.172 4,37	0.218 5,54	24.20 614,7
26 O.D. 650	26.000 660,4	0.093 2,36	0.031 0,79	1.75 44,45	0.625 15,88	25.50 647,7	-0.063 -1,60	0.250 6,35	0.250 6,35	26.20 665,5
28 O.D. 700	28.000 711,0	0.093 2,36	0.031 0,79	1.75 44,45	0.625 15,88	27.50 698,50	-0.063 -1,60	0.250 6,35	0.250 6,35	28.20 716,3
30 O.D. 750	30.000 762,0	0.093 2,36	0.031 0,79	1.75 44,45	0.625 15,88	29.50 749,30	-0.063 -1,60	0.250 6,35	0.250 6,35	30.20 767,1
32 O.D. 800	32.000 813,0	0.093 2,36	0.031 0,79	1.75 44,45	0.625 15,88	31.50 800,10	-0.063 -1,60	0.250 6,35	0.250 6,35	32.20 817,9
36 O.D. 900	36.000 914,0	0.093 2,36	0.031 0,79	1.75 44,45	0.625 15,88	35.50 901,70	-0.063 -1,60	0.250 6,35	0.250 6,35	36.20 919,5
42 O.D. 1050	42.000 1067,0	0.093 2,36	0.031 0,79	2.00 50,80	0.625 15,88	41.50 1054,10	-0.063 -1,60	0.250 6,35	0.250 6,35	42.20 1071,8

† On roll grooved pipe, Allowable Pipe End Separation and Deflection from Centerline will be 1/2 values listed for cut grooved pipe. For 30 - 42" (750 - 1050 mm) roll groove dimensions contact Victaulic.

COLUMN 1: **Nominal IPS Pipe size.**

COLUMN 2: **IPS outside diameter.** The outside diameter of roll grooved pipe shall not vary more than the tolerance listed. For IPS pipe the maximum allowable tolerance from square cut ends is 0.030" for 3/4 - 3 1/2"; 0.045" for 4 - 6"; and 0.060" for sizes 8" O.D. and above measured from true square line.

COLUMN 3: **Gasket seat.** The pipe surface shall be free from indentations, roll marks, and projections from the end of the pipe to the groove, to provide a leak-tight seal for the gasket. All loose paint, scale, dirt, chips, grease and rust must be removed. It continues to be Victaulic's first recommendation that pipe be square cut. When using beveled pipe contact Victaulic for details. Square cut pipe **must** be used with FlushSeal® and EndSeal® gaskets. Gasket seat "A" is measured from the end of the pipe. IMPORTANT: Roll grooving of beveled end pipe may result in unacceptable pipe end flare. See column 8.

COLUMN 4: **Groove width.** Bottom of groove to be free of loose dirt, chips, rust and scale that may interfere with proper coupling assembly. Corners at bottom of groove must be radiused. For IPS steel pipe, .06R on 3/4 - 1 1/2", .08R on 2 - 6", .05R on 8" and up.


COLUMN 5: **Groove outside diameter.** The groove must be of uniform depth for the entire pipe circumference. Groove must be maintained within the "C" diameter tolerance listed.

COLUMN 6: **Groove depth.** For reference only. Groove must conform to the groove diameter "C" listed.

COLUMN 7: **Minimum allowable wall thickness.** This is the minimum wall thickness which may be roll grooved.

COLUMN 8: **Maximum allowable pipe end flare diameter.** Measured at the most extreme pipe end diameter square cut or beveled.

# STANDARD CUT GROOVE SPECIFICATIONS FOR STEEL AND OTHER IPS PIPE



Cut grooving standard steel pipe removes less metal, to less depth, than threading, maintaining the desired integrity of the pipe.

Victaulic flexible coupling performance data reflects roll grooving specifications. For standard cut grooved pipe the Allowable Pipe End Separation and Deflection figures may be doubled. Refer to Notes with the specific type coupling used.

## Standard Cut Groove Specifications

1 Nom. Pipe Size Inches mm	2		3	4	5		6	7	
	Dimensions – Inches/millimeters								
	Pipe Outside Dia. O.D.			Gasket Seat - A ±0.03 ±0.76	Grv. Width - B ±0.03 ±0.76	Groove Dia. – C		Groove Depth D (ref.)	Min. Allow. Wall Thk. T
	Basic	Tolerance +      -				Basic	Tol. +0.000 +0.00		
3/4 20	1.050 26,9	0.010 0,25	0.010 0,25	0.625 15,88	0.313 7,95	0.938 23,83	-0.015 -0,38	0.056 1,42	0.113 2,87
1 25	1.315 33,7	0.013 0,33	0.013 0,33	0.625 15,88	0.313 7,95	1.190 30,23	-0.015 -0,38	0.063 1,60	0.133 3,38
1 1/4 32	1.660 42,4	0.016 0,41	0.016 0,41	0.625 15,88	0.313 7,95	1.535 38,99	-0.015 -0,38	0.063 1,60	0.140 3,56
1 1/2 40	1.900 48,3	0.019 0,48	0.019 0,48	0.625 15,88	0.313 7,95	1.775 45,09	-0.015 -0,38	0.063 1,60	0.145 3,68
2 50	2.375 60,3	0.024 0,61	0.024 0,61	0.625 15,88	0.313 7,95	2.250 57,15	-0.015 -0,38	0.063 1,60	0.154 3,91
2 1/2 65	2.875 73,0	0.029 0,74	0.029 0,74	0.625 15,88	0.313 7,95	2.720 69,09	-0.018 -0,46	0.078 1,98	0.188 4,78
76,1 mm	3.000 76,1	0.030 0,76	0.030 0,76	0.625 15,88	0.313 7,95	2.845 72,26	-0.018 -0,46	0.078 1,98	0.188 4,78
3 80	3.500 88,9	0.035 0,89	0.031 0,79	0.625 15,88	0.313 7,95	3.344 84,94	-0.018 -0,46	0.078 1,98	0.188 4,78
3 1/2 90	4.000 101,6	0.040 1,02	0.031 0,79	0.625 15,88	0.313 7,95	3.834 97,38	-0.020 -0,51	0.083 2,11	0.188 4,78
4 100	4.500 114,3	0.045 1,14	0.031 0,79	0.625 15,88	0.375 9,53	4.334 110,08	-0.020 -0,51	0.083 2,11	0.203 5,16
4 1/2 120	5.000 127,0	0.050 1,27	0.031 0,79	0.625 15,88	0.375 9,53	4.834 122,78	-0.020 -0,51	0.083 2,11	0.203 5,16
139,7 mm	5.500 139,7	0.056 1,42	0.031 0,79	0.625 15,88	0.375 9,53	5.334 135,48	-0.020 -0,51	0.083 2,11	0.203 5,16
5 125	5.563 141,3	0.056 1,42	0.031 0,79	0.625 15,88	0.375 9,53	5.395 137,03	-0.020 -0,51	0.084 2,13	0.203 5,16
152,4 mm	6.000 152,4	0.056 1,42	0.031 0,79	0.625 15,88	0.375 9,53	5.830 148,08	-0.022 -0,56	0.085 2,16	0.219 5,56
165,1 mm	6.500 165,1	0.063 1,60	0.031 0,79	0.625 15,88	0.375 9,53	6.330 160,78	-0.022 -0,56	0.085 2,16	0.219 5,56
6 150	6.625 168,3	0.063 1,60	0.031 0,79	0.625 15,88	0.375 9,53	6.455 163,96	-0.022 -0,56	0.085 2,16	0.219 5,56
203,2 mm	8.000 203,2	0.063 1,60	0.031 0,79	0.750 19,05	0.438 11,13	7.816 198,53	-0.022 -0,56	0.092 2,34	0.238 6,05
8 200	8.625 219,1	0.063 1,60	0.031 0,79	0.750 19,05	0.438 11,13	8.441 214,40	-0.025 -0,64	0.092 2,34	0.238 6,05
254,0 mm	10.000 254,0	0.063 1,60	0.031 0,79	0.750 19,05	0.500 12,70	9.812 249,23	-0.025 -0,64	0.094 2,39	0.250 6,35
10 250	10.750 273,0	0.063 1,60	0.031 0,79	0.750 19,05	0.500 12,70	10.562 268,28	-0.027 -0,69	0.094 2,39	0.250 6,35
304,8 mm	12.000 304,8	0.063 1,60	0.031 0,79	0.750 19,05	0.500 12,70	11.781 299,24	-0.027 -0,69	0.109 2,77	0.279 7,09
12 300	12.750 323,9	0.063 1,60	0.031 0,79	0.750 19,05	0.500 12,70	12.531 318,29	-0.030 -0,76	0.109 2,77	0.279 7,09
14 350	14.000 355,6	0.063 1,60	0.031 0,79	0.938 23,83	0.500 12,70	13.781 350,04	-0.030 -0,76	0.109 2,77	0.281 7,14
15 375	15.000 381,0	0.063 1,60	0.031 0,79	0.938 23,83	0.500 12,70	14.781 375,44	-0.030 -0,76	0.109 2,77	0.312 7,92

\* 9/16" (14 mm) width groove is required in sizes 22 - 24" (550 - 600 mm) in order to obtain the maximum allowable pipe end movement listed in Performance Data Charts. 1/2" (12 mm) width groove will give 1/2 the maximum allowance shown for 22 - 24" (550 - 600 mm). For double groove tool bit information, contact Victaulic.

COLUMN 1: **Nominal IPS Pipe size.**

COLUMN 2: **IPS outside diameter.** The outside diameter of cut grooved pipe shall not vary more than the tolerance listed. For IPS pipe the maximum allowable tolerance from square cut ends to 0.030" for 3/4 - 3 1/2"; 0.045" for 4 - 6"; and 0.060" for sizes 8" O.D. and above measured from true square line.

COLUMN 3: **Gasket seat.** The pipe surface shall be free from indentations, roll marks, and projections from the end of the pipe to the groove, to provide a leak-tight seal for the gasket. All loose paint, scale, dirt, chips, grease and rust must be removed. It continues to be Victaulic's first recommendation that pipe be square cut. When using beveled pipe contact Victaulic for details. Square cut pipe **must** be used with FlushSeal® and EndSeal® gaskets. Gasket seat "A" is measured from the end of the pipe.

COLUMN 4: **Groove width.** The bottom of groove to be free of loose dirt, chips, rust and scale that may interfere with proper coupling assembly. Maximum permissible radius at bottom of groove is .015".

COLUMN 5: **Groove outside diameter.** The groove must be of uniform depth for the entire pipe circumference. Groove must be maintained within the "C" diameter tolerance listed.

COLUMN 6: **Groove depth.** For reference only. Groove must conform to the groove diameter "C" listed.

COLUMN 7: **Minimum allowable wall thickness.** This is the minimum wall thickness which may be cut grooved.

## Standard Cut Groove Specifications

1 Nom. Pipe Size Inches mm	2		3		4		5		6	7
	Dimensions – Inches/millimeters									
	Pipe Outside Dia. O.D.			Gasket Seat - A ±0.03 ±0,76	Grv. Width - B ±0.03 ±0,76	Groove Dia. – C		Groove Depth D (ref.)	Min. Allow. Wall Thk. T	
	Basic	Tolerance +      -				Basic	Tol. +0.000 +0,00			
16	16.000	0.063	0.031	0.938	0.500	15.781	-0.030	0.109	0.312	
100	406,4	1,60	0,79	23,83	12,70	400,84	-0,76	2,77	7,92	
18	18.000	0.063	0.031	1.000	0.500	17.781	-0.030	0.109	0.312	
450	457,2	1,60	0,79	25,40	12,70	451,64	-0,76	2,77	7,92	
20	20.000	0.063	0.031	1.000	0.500	19.781	-0.030	0.109	0.312	
500	508,0	1,60	0,79	25,40	12,70	502,44	-0,76	2,77	7,92	
22	22.000	0.063	0.031	1.000	0.563*	21.656	-0.030	0.172	0.375	
550	559,0	1,60	0,79	25,40	14,30	550,06	-0,76	4,37	9,53	
24	24.000	0.063	0.031	1.000	0.563*	23.656	-0.030	0.172	0.375	
600	610,0	1,60	0,79	25,40	14,30	600,86	-0,76	4,37	9,53	
26 O.D.	26.00	0.093	0.031	1.75	0.625	25.50	-0.063	0.250	0.625	
650	660,4	2,36	0,79	44,45	15,88	647,7	-1,60	6,35	15,88	
28 O.D.	28.00	0.093	0.031	1.75	0.625	27.50	-0.063	0.250	0.625	
700	711,0	2,36	0,79	44,45	15,88	698,50	-1,60	6,35	15,88	
30 O.D.	30.00	0.093	0.031	1.75	0.625	29.50	-0.063	0.250	0.625	
750	762,0	2,36	0,79	44,45	15,88	749,30	-1,60	6,35	15,88	
32 O.D.	32.00	0.093	0.031	1.75	0.625	31.50	-0.063	0.250	0.625	
800	813,0	2,36	0,79	44,45	15,88	800,10	-1,60	6,35	15,88	
36 O.D.	36.00	0.093	0.031	1.75	0.625	35.50	-0.063	0.250	0.625	
900	914,0	2,36	0,79	44,45	15,88	901,70	-1,60	6,35	15,88	
42 O.D.	42.00	0.093	0.031	2.00	0.625	41.50	-0.063	0.250	0.625	
1050	1067,0	2,36	0,79	50,80	15,88	1054,10	-1,60	6,35	15,88	

\*  $\frac{9}{16}$ " (14 mm) width groove is required in sizes 22 - 24" (550 - 600 mm) in order to obtain the maximum allowable pipe end movement listed in Performance Data Charts.  $\frac{1}{2}$ " (12 mm) width groove will give  $\frac{1}{2}$  the maximum allowance shown for 22 - 24" (550 - 600 mm). For double groove tool bit information, contact Victaulic.

COLUMN 1: **Nominal IPS Pipe size.**

COLUMN 2: **IPS outside diameter.** The outside diameter of cut grooved pipe shall not vary more than the tolerance listed. For IPS pipe the maximum allowable tolerance from square cut ends to 0.030" for  $\frac{3}{4}$  - 3 $\frac{1}{2}$ "; 0.045" for 4 - 6"; and 0.060" for sizes 8" O.D. and above measured from true square line.

COLUMN 3: **Gasket seat.** The pipe surface shall be free from indentations, roll marks, and projections from the end of the pipe to the groove, to provide a leak-tight seal for the gasket. All loose paint, scale, dirt, chips, grease and rust must be removed. It continues to be Victaulic's first recommendation that pipe be square cut. When using beveled pipe contact Victaulic for details. Square cut pipe **must** be used with FlushSeal® and EndSeal® gaskets. Gasket seat "A" is measured from the end of the pipe.

COLUMN 4: **Groove width.** The bottom of groove to be free of loose dirt, chips, rust and scale that may interfere with proper coupling assembly. Maximum permissible radius at bottom of groove is .015".

COLUMN 5: **Groove outside diameter.** The groove must be of uniform depth for the entire pipe circumference. Groove must be maintained within the "C" diameter tolerance listed.

COLUMN 6: **Groove depth.** For reference only. Groove must conform to the groove diameter "C" listed.

COLUMN 7: **Minimum allowable wall thickness.** This is the minimum wall thickness which may be cut grooved.